

Evidence of Performance

Burglar resistance



Test Report

No. 12-001990-PR01
(PB-C02-05-en-01)

Client	TOTUM prekyba Kauno 35/48-9 03215 Vilnius Lithuania
Product	Burglar resistant doorset
Designation	Totum 3
Overall dimensions (W x H)	1,105 mm x 2,200 mm
(Frame) Material, System	Steel
Attack side	Closing face as per EN 12519 and Opening face as per EN 12519
Type of opening	Single leaf
Glazing	-/-
Hardware	Three-point lock 672.28.OG / FIAM as per EN 12209, Pos. 7: 7 – Profile cylinder R6 / ISEO as per EN 1303, Pos. 7: 5, Pos. 8: 1 – Profile cylinder guide - 2 two-part hinges Item No. 1150/3739/ PETTITI GIUSEPPE S.p.A. - 4 pin retainers
Installation	According to the installation instructions by the client TOTUM prekyba
Special features	-/-

Basis

DIN EN 1627 : 2011
Pedestrian doorsets, windows,
curtain walling, grilles and
shutters – Burglar resistance –
Requirements and classification
DIN EN 1628 : 2011
DIN EN 1629 : 2011
DIN EN 1630 : 2011
Test Report 12-001990-PR01
(PB-C02-05-de-01) dated
22 November 2012
Representation



Instruction for use

The present test report serves to demonstrate the burglar resistance.

Validity

The data and results refer solely to the tested and described specimen. The burglar resistance test does not allow any statement to be made on any further characteristics of the present structure regarding performance and quality.

In deviation from the tested design the following size modifications are permitted:
in width +10% and -20%
in height +10% and -20%

Burglar resistance



RC 3

ift Rosenheim

28.02.2013

Konrad Querengässer, Dipl.-Ing. (FH)
Operating Product Officer
Building Components

Florian Willer, Dipl.-Ing. (FH)
Operating Testing Officer
Mechanics

Notes on publication

The ift-Guidance Sheet „Conditions and Guidance for the Use of ift Test Documents“ applies. The cover sheet can be used as an abstract.

Contents

The report contains a total of 33 pages
1 Object
2 Procedure
3 Detailed results
Annex 1 (11 pages)
Annex 2 (2 pages)
Annex 3 (4 pages)



ift Rosenheim GmbH
Geschäftsführer:
Dr. Jochen Peichl
Prof. Ulrich Sieberath
Dr. Martin H. Spitzner

Theodor-Gietl-Str. 7 - 9
D-83026 Rosenheim
Tel.: +49 (0)8031/261-0
Fax: +49 (0)8031/261-290
www.ift-rosenheim.de

Sitz: 83026 Rosenheim
AG Traunstein, HRB 14763
Sparkasse Rosenheim
Kto. 3822
BLZ 711 500 00

Notified Body Nr.: 0757
Anerkannte PÜZ-Stelle: BAY 18

DAP-ZE-2288.00
DGA-IS-4285-00



Deutsche
Akkreditierungsstelle
D-PL-11349-01-00
D-ZM-11349-01-00